



**Instruction and Installation Manual
for
Programmable K-Factor Scaler Board
Model: B220-885**

Blancett Flow Meters
100 East Felix St. South, Suite 190
Fort Worth, Texas 76115
817-920-9998
fax: 817-921-5282
www.blancett.com

Table of Contents

TABLE OF CONTENTS 2

SPECIFICATIONS..... 3

DESCRIPTION..... 4

OPERATION 4

INSTALLATION 5

POWER 5

TURBINE METER..... 5

PULSE OUTPUT 6

STARTUP AND CONFIGURATION 7

SOFTWARE 7

SETTING THE K-FACTOR 8

SETTING THE OUTPUT PULSE WIDTH..... 9

SETTING THE OUTPUT LEVEL NORMALLY HIGH OR NORMALLY LOW 9

SETTING THE OUTPUT PULSE TO USE THE INTERNAL OR EXTERNAL PULL-UP RESISTOR..... 9

Specifications

▼ External Power:

- Input Voltage – 8.5 to 30 Vdc (Diode protected)
- Maximum Current draw – 18mA (using internal resistor @ 30Vdc input)

▼ Environmental:

- OPERATING TEMPERATURE
-22° F (-30° C) to 158° F (70° C)

▼ Inputs:

- MAGNETIC PICKUP INPUT:
Frequency Range: 0 to 4000 Hz
Trigger Sensitivity: 30 mV p-p to 30 V p-p

▼ Output Signal

- Max. Voltage = 30Vdc
- Max Power = 0.25W
- Pulse Type (using internal pull-up resistor)
 V_H = Power Input Voltage – 0.7Vdc
 V_L = Less then 0.4V @ max input power
- Pulse Type (using external pull-up resistor)
 V_H = Input Voltage to external pull-up resistor
 V_L = $(V_H / (\text{selected resistor value} + 47\Omega)) * 47\Omega$
- Pulse Length: 150us, 1ms, 25ms, 100ms, 500ms, 1s, or Auto mode selectable.

▼ Internal Pull-up Resistor

- Jumper disable option
- 3.6K Ω

▼ Enclosure

- Killark aluminum capped elbow -Y3
- CSA approved Class I, Div. 1 & 2, Groups C, D; Class II, Div 1 & 2, Groups E,F, and G; and Class III

▼ Agency Listings

- CSA - “Ordinary Locations”
Pollution Degree 2, Overvoltage Category III

Definitions:

Pollution Degree 2: Normally only non-conductive Pollution occurs. Occasionally, however, a temporary conductivity caused by condensation must be expected.

Overvoltage Category III: Distribution level, fixed installation, with smaller transient overvoltage than installation category IV (Primary supply level).

Important: For this CSA rating to be valid, the circuit board assembly must be mounted in a certified Killark 1” NPT model Y-3 conduit outlet box.

Description

The Blancett K-factor Scaler board is a field adjustable frequency divider, which interfaces the output signal from a turbine meter with a magnetic pickup to the input of a PLC, RTU, CPU data acquisition card, or similar totalizer device. The adjustable frequency divisor, referred to as the K-factor, allows the pulses being sent from a turbine meter to be divided into a recognizable unit that an end device, such as a PLC can count and display.

Different K-factors allow the end device to display in any number of volume measurements such as gallons, cubic meter, liters, barrels, and so forth. A calibration sheet provided with a turbine meter will list a nominal K-factor (for the range of the meter) tested to a specific volumetric flow rate. This K-factor can be placed directly into the K-factor board to provide an output with the same volumetric flow rate or modified to a different volumetric flow rate by re-calculating the K-factor with the appropriate conversion factor.

In addition, if the K-factor is set to 1, the K-factor Scaler board can be used as a pre-amplifier where the frequency from a low-level turbine meter is proportional to the logic level frequency output needed by a PLC or CPU data acquisition card. This option allows the end device to control the dividing process of the turbine meter output to a recognizable flow rate.

Operation


Fluid moving through a turbine flow meter causes the rotor to rotate in relation to the flow rate. The rotation of the rotor blades cuts through the magnetic field generated by the magnetic pick-up which in turn generates a frequency output signal that is directly proportional to the speed of the rotor.

The signal produced is received by the K-factor Scaler board input amplifier, which has an input sensitivity of 30mV p-p to 30V p-p. The signal is then sent to an onboard microcontroller, which acts as a divisor with a range of 1 to 999,999,999. The divisor (K-factor) is user adjustable and set by programming it into the board. The microcontroller handles the dividing process by counting the input pulses and comparing it to the programmed K-factor value. Once the count equals this value, an output pulse occurs for a selectable time period and the counting process starts over.

Installation

The programmable K-factor Scaler board was designed to provide a lower cost alternative to the Blancett model B220-880 K-factor board. The programmable version allows fewer components to be used which reduces the size of the board and enclosure. Refer to Diagram 1 below for the I/O terminal connections. The board connections include Power Input, Turbine Meter Input, and the Pulse Output to a totalizing device.

Diagram 1. Board Connections



Enclosure Mounting (necessary for CSA certification)

If the circuit board assembly is supplied without an enclosure, it must be mounted within a certified Killark 1" NPT model Y-3 conduit elbow outlet box to maintain the CSA "Ordinary Locations" certification.

Power

The K-factor board requires 8.5 - 30VDC to operate. The power connections are reverse polarity protected by a diode but must be connected properly for operation of the device. Polarity is shown in Diagram 1 above.

Turbine Meter

The Turbine Meter connections are non-polarized. Shielded twisted pair wire is recommended for this connection to the Turbine meter.

Pulse Output

Either the internal pull-up resistor or an external resistor **must** be used for the K-factor Scaler board to provide an output pulse. This option is controlled by the on-board jumper. With the jumper installed, the internal pull-up resistor is connected.

Internal Pull-up Resistor

The internal pull-up resistor allows for a simple installation but care must be taken to ensure that the device being connected to by the pulse output can handle voltage levels as high as the power feeding the K-factor board. Another important setup consideration when using the internal pull-up resistor is to make sure the output pulse from the K-factor board can supply enough current for the receiving device to be able to read the pulse. The available current that the K-factor Board can supply the receiving device can be calculated with the following equation.

$$AvailableCurrent = \left(\frac{InputVoltage - 0.7V}{3600\Omega + 47\Omega} \right)$$

Verify that the receiving device input current requirement is below this value for proper operation. Otherwise, an external pull-up resistor less than 3.6K Ω will have to be used.

External Pull-up Resistor

Using an external pull-up resistor offers the end user greater flexibility of controlling the output pulse provided by the K-factor board to a receiving device. Since power sources and receiving devices differ between users, different resistor values may be required by different setups.

The external pull-up resistor is connected between the receiving device's input and a power source. This power source would be the maximum input voltage (of the pulse) to the receiving device. Refer to the following equation to help determine the resistor value needed.

$$R = \left(\frac{SupplyVoltage}{I} \right)$$

Where: **R** = the Resistor value in ohms

Supply Voltage = the supply voltage connected to the external pull-up resistor

I = the input current required by the receiving device in amps

After the Resistor value has been calculated, make sure in the following equation, that "P" is less than or equal to 0.25. "P" represent the power capability of the output and should not exceed 0.25 Watts. Exceeding this value could damage the K-factor Board. Raising the Resistor value will decrease the power calculation.

$$P = (SupplyVoltage) \left(\frac{SupplyVoltage}{R + 47} \right)$$

Startup and Configuration


Software

The programmable K-factor Scaler board can be factory or user configured through a serial port of a PC by a Windows based software utility. A programming adapter is required that interfaces the serial port from the PC to the programming port on the board.

To program the K-factor Scaler board, connect the adapter cable to the board and make sure power is being supplied. Power must be supplied to the K-factor Scaler board in order to program the device.

The programming software is divided into two columns as shown in Diagram 2. The 'Program Values' column is the information that is to be programmed into the K-factor board and can be entered by the user. The 'Board Values' column contains the information that the K-factor board currently contains and can not be altered by the user. The 'Board Values' column will only display the contents of the board after a program, read, or verify function was performed.

Diagram 2. Programming Software Screenshot



The proper serial port must be selected within the Blancett K-factor Programming software for data to be programmed or read from the board. This is done by going to TOOLS – COM PORT, from the menu bar, and selecting the Com Port (1 through 4) that the serial programming cable is connected to on the computer.

If the serial port selected is invalid, the software will show the message “ERROR- Invalid Com Port” when trying to program the board. If the serial port selected is the incorrect port (or if there is a problem with the cable), the software will show the message “<< No Response>>” after trying to program the board. All information under the ‘Program Values’ column must be entered before the software will allow the board to be programmed.

The PROGRAM button programs the K-factor, Pulse Width , and Pulse Output to the K-factor board. After the program function is complete, the board is automatically read and verified. The K-factor Board will retain these values when disconnected from power and can be re-programmed at any time.

The READ button reads the current information from the K-factor board and displays it under the ‘Board Values’ column of the PC software.

The VERIFY button performs the same function as the READ button but compares the Board Values to the Program Values and displays an error if the two do not match.

Configuring and programming the K-factor Board consists of the following four items:

- 1) Setting the K-factor (divider)
- 2) Setting the output pulse width
- 3) Setting the output level normally high or normally low
- 4) Setting the pulse to use the internal or external pull-up resistor

Setting the K-factor

The K-factor is the ratio of input pulses per each output pulse and can be viewed as a divisor. The minimum K-factor can be set to 1 where each input pulse yields an output pulse. The maximum K-factor can be set to 999,999,999 where it would take this many input pulses to yield one output pulse.

The K-factor is set by entering it into the ‘Program Values’ column of the software under K-Factor. The K-factor will be programmed into the board when the Program button is pressed but note that all values must be entered before programming is allowed by the software.

Setting the Output Pulse Width

The output pulse width is the length of time the pulse remains active before resetting to its resting state. The K-factor Scaler board has a total of six different pulse widths to choose from. Some end devices require that the pulse be a certain length or longer in order for proper detection of each incoming pulse. For these devices, it's important to select a pulse width that is long enough for the end device to recognize.

The pulse width option is set by selecting the desired pulse width radio button in the 'Program Values' column of the software. The Pulse Width option will be programmed into the board when the Program button is pressed but note that all values must be entered before programming is allowed by the software.

In addition to six pre-set pulse widths to choose from, another option is also available called "Auto" mode. This mode acts in the same manor but does not restrain the output pulse to a specific length. Instead, it varies and is dependent on output frequency. The higher the output frequency, the shorter the pulse width output. The lower the frequency output, the longer the pulse width output. This option turns off the 'Pulse Output' option because it does not apply in this mode.

Setting the output level normally high or normally low

Most end devices will be unaffected by this setting but the K-factor Scaler board has the ability to invert the output pulse level. This option is set by selecting the desired pulse output radio button in the 'Program Values' column of the software. The Pulse Output option will be programmed into the board when the Program button is pressed but note that all values must be entered before programming is allowed by the software.

When the Pulse Output option "High" is selected, the output level is normally low and the duration of the selected pulse width is high. When the Pulse Output option "Low" is selected, the output level is normally high and the duration of the selected pulse width is low.

Setting the output pulse to use the internal or external pull-up resistor

Either the internal pull-up resistor or an external resistor **must** be used for the K-factor Scaler board to provide an output pulse. This option is controlled by the on-board jumper and not by software.

With the jumper installed, the internal 3.6K pull-up resistor is connected to the input voltage of the board. With the jumper uninstalled, the internal pull-up resistor is disconnected and an external pull-up resistor and supply voltage is required.